

Article 23

Police Station Basement and Exterior Drainage Improvements \$50,000
(Permanent Building Committee (PBC) – Priority Project)

What Is Article For?


- Requesting Funds to Provide Short and Long-Term Health and Safety Improvements for Police Staff and for Protection of Town Asset.
- Repairs Will Address Ground and Surface Water from Entering Building to Eliminate Damage to Town Asset.

Police Station Basement and Exterior Drainage Improvements \$50,000 (Permanent Building Committee (PBC) – Priority Project)



Water in Electrical Room
Solar Equipment and Main Electrical Panel

Police Station Basement and Exterior Drainage Improvements \$50,000
(Permanent Building Committee (PBC) – Priority Project)



Groundwater From Electrical Conduits

Police Station Basement and Exterior Drainage Improvements \$50,000 (Permanent Building Committee (PBC) – Priority Project)



Surface Runoff Enters Through Garage Door
(Sandbags Required)

Article 23

Police Station Basement and Exterior Drainage Improvements \$50,000
(Permanent Building Committee (PBC) – Priority Project)

How to Resolve Issues?

- Install Sump Pump in the Basement to Maintain Groundwater Level Below Finish Grade of Basement Floor.
- Minor Grading Changes and Drains to Redirect Runoff From Building Entrances.